

CONTROL OF SUBSTANCES HAZARDOUS TO HEALTH HAZARD ASSESSMENT FORM

Company: J T BEVANN DRYLINING SPECIALISTS LTD

Assessment Date: 08/04

Substances:
PLASTERBOARDS

Category:
Gypsum based accessories are
not classified as hazardous under
COSHH Regulations EH40 2002

Nature of Health Risk:

Dust from sawing or sanding may irritate the
respiratory system, skin and eyes.

Toxic
Harmful
Corrosive
Irritant ✓

Control Measures:

(including Manufacturer's Advice)

Skin – Wash with clean water and soap.

Eyes – Irrigate with clean water

Inhalation – Remove person to fresh air.

Ingestion – Wash out mouth and drink plenty of water.

Seek medical attention should any symptoms persist.

Protective Equipment:

Local ventilation ✓
Face Masks ✓
Goggles ✓
Gloves ✓
Barrier creams ✓
Overalls

Results of air monitoring:

Levels Recorded: N/A

Health Surveillance Needed:

N/A

Identify any susceptible employees:

Site Operatives

Special Precautions arising from:

Fire: NONE
Spillage: NONE
Mixture: NONE

Person making assessment:

Signature:.....