

J T BEVANN DRYLINING SPECIALISTS LTD

WORKPLACE RISK ASSESSMENT NUMBER: 018				DATE: 30.09.04.			
LOCATION							
OPERATION/PROCESS WORKING WITH ELECTRIC POWER TOOLS				MANUAL HANDLING ASSESSMENT N/A			
EQUIPMENT USED Electric tools				COSHH ASSESSMENT N/A			
SUBSTANCES USED 110 volt electricity				NOISE ASSESSMENT To be assessed			
Hazards Identified				Before Controls		After Controls	
				L	M	H	
Struck by tool				X			
Electric shock				X			
Contamination from the substance being worked with				X			
Exposed Persons: Operative							
FREQUENCY OF EXPOSURE Various				DURATION OF EXPOSURE Various			
CONTROL MEASURES P.P.E. INSTRUCTION/INFORMATION/TRAINING Goggles/visors to BS EN 166B Gloves, dust masks and other PPE as indicated by the COSHH data of the substance being used. Hearing protection to be used if indicated by noise monitoring. Electric cables are to be checked daily for abrasion/damage. Comply with Electricity at Works Regulations: All tools to be uniquely marked, tagged and maintenance logged. Clear up debris regularly. Ensure trained/experienced operator.							
MONITORING RESULTS							
ASSESSOR				POSITION			